

# NASA TECHNICAL MEMORANDUM

NASA TM X-64883

## TEMPERATURE RISE OF FLAT CONDUCTOR CABLE INSTALLED UNDER CARPET

(NASA-TM-X-64883) TEMPERATURE RISE OF  
FLAT CONDUCTOR CABLE INSTALLED UNDER  
CARPET (NASA) 13 p HC \$3.00 CSCL 09C

N74-34643

Unclas

G3/C9 50993

James D. Hankins  
Electronics and Control Laboratory

September 1974

NASA

*George C. Marshall Space Flight Center  
Marshall Space Flight Center, Alabama*

TECHNICAL REPORT STANDARD TITLE PAGE

1. REPORT NO. NASA TM X-64883	2. GOVERNMENT ACCESSION NO.	3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE  Temperature Rise of Flat Conductor Cable Installed Under Carpet		5. REPORT DATE September 1974	
		6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S) James D. Hankins		8. PERFORMING ORGANIZATION REPORT #	
9. PERFORMING ORGANIZATION NAME AND ADDRESS George C. Marshall Space Flight Center Marshall Space Flight Center, Alabama 35812		10. WORK UNIT NO.	
		11. CONTRACT OR GRANT NO.	
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, D. C. 20546		13. TYPE OF REPORT & PERIOD COVERED  Technical Memorandum	
		14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES Prepared by Electronics and Control Laboratory, Science and Engineering			
16. ABSTRACT  This report contains the method, test data, and results of temperature rise tests on flat conductor cable installed under carpet and powered at up to twice rated loads.			
17. KEY WORDS Flat Conductor Cabling House Wiring Electrical Wiring		18. DISTRIBUTION STATEMENT Unclassified-unlimited  <i>E. Brooks Moore</i>	
19. SECURITY CLASSIF. (of this report) Unclassified	20. SECURITY CLASSIF. (of this page) Unclassified	21. NO. OF PAGES 14	22. PRICE NTIS

## TABLE OF CONTENTS

	Page
INTRODUCTION . . . . .	1
PURPOSE AND TEST SETUP . . . . .	1
TEST RESULTS AND CONCLUSIONS . . . . .	3
BIBLIOGRAPHY OF SELECTED GOVERNMENT AND INDUSTRY DOCUMENTS . . . . .	5

## LIST OF ILLUSTRATIONS

Figure	Title	Page
1.	Cross section of FCC installed under carpet . . . . .	2
2.	Electrical test setup . . . . .	2
3.	Temperature rise versus load of AWG No. 12 (copper) FCC installed under carpet . . . . .	4

## LIST OF TABLES

Table	Title	Page
1.	FCC Temperature Data for Installation Under Carpet . . . . .	3

## TEMPERATURE RISE OF FLAT CONDUCTOR CABLE INSTALLED UNDER CARPET

### INTRODUCTION

Flat conductor cable (FCC), as a spinoff of aerospace developed technology, is highly desirable for use as residential, commercial, and industrial electrical wiring because of low installation costs. The shape of the FCC is one of the factors contributing to low installation costs; FCC is thin and for most practical purposes has only two dimensions, width and length. This thinness allows FCC to be attractively installed using techniques and in a manner not practical with conventional round wires; e.g., under carpet, under tile, behind paneling, under wallpaper, and surfaced-mounted on walls and ceilings. FCC is embryonic as a wiring system and, consequently, is not adequately covered by current electrical codes and standards.

### PURPOSE AND TEST SETUP

Tests were conducted to determine the temperature rise resulting from the electrical load of three-conductor, AWG No. 12 FCC installed under carpet on wood and on asphalt tiled, concrete floors.

The cable tested was 5.08 cm (2 in.) wide by 0.76 mm (0.030 in.) thick, with three copper conductors, 0.31 mm by 10 mm (0.012 in. by 0.400 in.), laminated between 0.23-mm (0.009-in.) films of Mylar-vinyl insulation. The conditions were simulated by installing cable, shield [0.15 m by 1.8 m (6 in. by 6 ft)], 0.48-cm (0.1875-in.) sponge carpet padding [0.6 m by 1.8 m (2 ft by 6 ft)], and short pile carpet [0.6 m by 1.8 m (2 ft by 6 ft)] on 1.9-cm (0.75-in.) plywood and tiled concrete as shown in Figure 1. The center conductor was not powered during the test. Thermocouples were placed above and below one of the loaded conductors to measure the shield/padding interface temperature and the cable/floor interface temperature. The cable was electrically connected as shown in Figure 2.




Figure 1. Cross section of FCC installed under carpet.




Figure 2. Electrical test setup.

## TEST RESULTS AND CONCLUSIONS

As expected, there were no temperature rise problems with the FCC even at over twice the rated load of the cable. Previous testing\* of aerospace FCC has shown that single layers of flat conductors in air can be rated at 150 percent of that of equally sized round wires. This advantage is because of the high ratio of surface area to volume of FCC.

Table 1 and Figure 3 show the test data and curves. The temperature of the carpet surface was not measured, but even at the higher loads it was barely warm to the touch. It is noted that the asphalt tile acted as a thermal barrier and that cable installations on "bare concrete" would have lower temperature rises for respective current levels.

The test results show that the temperature rise of FCC installed under carpet presents no problem. In all cases, the carpet was pleasant to touch and materials were not degraded.

TABLE 1. FCC<sup>a</sup> TEMPERATURE DATA FOR  
INSTALLATION UNDER CARPET

LOAD (Amps)	T <sub>1</sub> (°C)	T <sub>2</sub> (°C)	T <sub>3</sub> (°C)	T <sub>4</sub> (°C)	T <sub>5</sub> (°C)
15	1.11	0.56	3.33	2.22	21.11
20	2.78	2.22	7.22	5.00	21.11
30	6.11	5.56	16.67	12.22	21.11
40	11.11	10.00	33.33	22.78	21.11
45	15.56	14.44	44.44	33.33	21.11

a. Three copper conductors, AWG No. 12 equivalent, Mylar-vinyl insulation.

NOTES: 1. T<sub>1</sub> is cable/floor interface temperature on tile floor.  
2. T<sub>2</sub> is shield/padding interface temperature on tile floor.  
3. T<sub>3</sub> is cable/floor interface temperature on wood floor.  
4. T<sub>4</sub> is shield/padding interface temperature on wood floor.  
5. T<sub>5</sub> is room temperature.  
6. See Figure 3 for plotted curves.

---

\*Documented in NASA TM X-54767, The Load-Carrying and Thermal Characteristics of Flat Conductor Cable, August 1973.




Figure 3. Temperature rise versus load of AWG No. 12 (copper) FCC installed under carpet.



## BIBLIOGRAPHY OF SELECTED GOVERNMENT AND INDUSTRY DOCUMENTS

### Specifications and Standards

IPC-FC-218A, General Specification for Connectors, Electrical, Flexible FC Type, September 1968.

IPC-FC-220, Specification for FCC, Unshielded, May 1970.

IPC-FC-230A, Handbook of Flat Cable, Revised June 1972.

MIL-C-55543, Cable, Electrical, Flat Multiconductor, Flexible, Unshielded, November 15, 1968.

MIL-C-55544, Connectors, Electrical, Environment Resistant, For Use with Flexible Flat Conductor Cable, General Specification for, December 26, 1968.

MSFC-SPEC-220B, Cable, Flat Conductor, Flexible, Electrical Copper, January 28, 1966.

MSFC-SPEC-219A, Connectors, Flat Conductor, Flexible Electrical Cable, May 5, 1966.

MSFC-SPEC-494A, Installation of Harness Assembly (Electrical Wiring), Space Vehicle.

### NASA Reports

Angele, W.: Flat Conductor Cable Manufacture and Installation Techniques. NASA TM X-53586, March 1967.

Angele, W.: Measuring the Conductor Spacing in Flat Conductor Cables. NASA TM X-53843, June 13, 1969.

Angele, W. and Hankins, J. D.: Flat Conductor Cable Design, Manufacture, and Installation. NASA TM X-53975, January 9, 1970.

Angele, W.; Martineck, Hans G.; Bennight, J D; and Hankins, J. D.: Flat Conductor Cable Connector Survey of 1970. NASA TM X-64613, July 1971.

## BIBLIOGRAPHY OF SELECTED GOVERNMENT AND INDUSTRY DOCUMENTS (Continued)

Angele, W.: Flat Conductor Cable for Electrical Packaging. NASA TM X-64667, January 21, 1972.

Angele, W.: Flat Conductor Cable Applications. NASA TM X-64672, March 1972.

Angele, W.: Flat Conductor Cable Connectors with Individually Sealed Contacts. NASA TM X-64695, August 1972.

Angele, W.: Termination of Flat Conductor Cable to NASA/MISFC Plugs. NASA TM X-64728, October 1972.

Astrionics Laboratory: Flat Conductor Technology Exemplified. NASA TM X-53584, March 1967.

Carden, James R.: Flat Conductor Cable for Limited Rotary or Linear Motion. NASA TM X-53960, October 1970.

Hankins, J. D. (Coordinator): Flat Conductor Cable Symposium, October 10-12, 1972. NASA TM X-64716, December 8, 1972.

Kennedy, B. W.: Evaluation of Adhesives for Installing Flat Conductor Cables. NASA TM X-53080, October 8, 1964.

Marshall Space Flight Center: Flat Conductor Cable Technology. SR-5043, Office of Technology Utilization, NASA, 1968.

Marshall Space Flight Center: Tools, Fixtures, and Test Equipment for Flat Conductor Cables. SP-5924 (01), Office of Technology Utilization, NASA, November 1968.

Marshall Space Flight Center: Manufacture and Quality Control of Interconnecting Wire Harnesses, Volume IV of IV. NASA TM X-64685, September 1, 1972.

Wilkinson, T. H.: Contact Resistance of Electroplated Flat Conductor Cable Conductors. NASA TM X-64542, July 15, 1970.

## BIBLIOGRAPHY OF SELECTED GOVERNMENT AND INDUSTRY DOCUMENTS (Continued)

### Internal Technical Reports

ED-15-70, Measurement of Bending Moment for Several Flat Conductor Cable Configurations.

ED-16-70, The Load Carrying and Thermal Characteristics of Flat Conductor Power Cable.

ED-1-71, Flex Testing Fixture for Flat Conductor Cable.

ED-2-71, Proposed Test Program for Measuring the Flexure Life of Flat Conductor Cable.

ED-8-71, A Preliminary Study on the Possibilities of Electronically Controlling a Flat Conductor Cable Brazing Tool.

ED-504, A Preliminary Study of Resistance Brazing Gold-Plated Flat Conductor Cable.

ED-505, Thermal Analysis of Proposed Flat Conductor Cable Lamination Method.

ED-510, Deflection Characteristics of Various Flat Conductor Cables.

ED-512, Qualification Testing Report of Cable, Electrical Multi-Conductor Unshielded, Flat, Flexible, Copper Conductors, 200°C, for Use in the Apollo Telescope Mount (ATM) Program.

ED-515, A Calculation of the Constriction Resistance of the FCC Individually Sealed Contact Connector Contacts.

ED-516, Flat Conductor Cable Equipment and Techniques.

ED-518, Tensile Tests of Flat Conductor Cable and Connectors.

ED-525, A Mathematical Model Describing the Thermal Behavior of Flat Conductor Cable Under Load.

## **BIBLIOGRAPHY OF SELECTED GOVERNMENT AND INDUSTRY DOCUMENTS (Concluded)**

**ED-526, Periodical Current and Voltage Propagation on FCC.**

**ED-527, Vibration Characteristics of Flat Conductor Cable.**

**ED-529, The Flexure Life of Flat Conductor Cable.**

**ED-530, Flat Conductor Cable Strength and Reinforcement Methods.**

**ED-533, A High Voltage Tester for Flat Conductor Cable Insulating Film.**

**ED-536, A Survey of Ground-Fault Circuit Interrupters for Use with Residential Wiring Systems.**

**ED-537, An Assembly Tool for Terminating Flat Conductor Cable to a Plug.**

**ED-539, Contact Resistance in the MSFC Individually Sealed Contact Connector for Flat Conductor Cable.**


## APPROVAL

### TEMPERATURE RISE OF FLAT CONDUCTOR CABLE INSTALLED UNDER CARPET

By James D. Hankins


The information in this report has been reviewed for security classification. Review of any information concerning Department of Defense or Atomic Energy Commission programs has been made by the MSFC Security Classification Officer. This report, in its entirety, has been determined to be unclassified.

This document has also been reviewed and approved for technical accuracy.



W. J. KRIEDER

Chief, Electronics Parts Development Branch



J. C. Taylor

Chief, Electronics Development Division



F. B. MOORE

Director, Electronics and Control Laboratory